

MU2R15

KOELEN

Aantal units	Combinatie van binnenunits (kBtu/h)					Totale capaciteit						Opgenomen (W)		
						Min		Nom.		Max				
	UNIT-A	UNIT-B	UNIT-C	UNIT-D	Totaal	Btu/h	kW	Btu/h	kW	Btu/h	kW	Min	Nom.	Max
1 unit	5				5	3.000	0,88	5.000	1,47	5.750	1,69	226	381	477
	7				7	4.200	1,23	7.000	2,05	8.050	2,36	303	540	683
	9				9	5.400	1,58	9.000	2,64	10.350	3,03	408	676	864
	12				12	7.200	2,11	12.000	3,52	13.800	4,04	540	926	1.176
2 units	5	5			10	6.000	1,76	10.000	2,93	11.500	3,37	414	682	889
	5	7			12	7.200	2,11	12.000	3,52	13.800	4,04	486	833	1.106
	5	9			14	8.400	2,46	14.000	4,10	16.100	4,72	583	988	1.376
	7	7			14	8.400	2,46	14.000	4,10	16.100	4,72	583	988	1.376
	7	9			16	8.400	2,46	14.000	4,10	16.100	4,72	583	988	1.376
	5	12			17	8.400	2,46	14.000	4,10	16.100	4,72	583	988	1.376
	9	9			18	8.400	2,46	14.000	4,10	16.100	4,72	583	988	1.376
	7	12			19	8.400	2,46	14.000	4,10	16.100	4,72	583	988	1.376
	9	12			21	8.400	2,46	14.000	4,10	16.100	4,72	583	988	1.376

VERWARMEN

Aantal units	Combinatie van binnenunits (kBtu/h)					Totale capaciteit						Opgenomen (W)		
						Min		Nom.		Max				
	UNIT-A	UNIT-B	UNIT-C	UNIT-D	Totaal	Btu/h	kW	Btu/h	kW	Btu/h	kW	Min	Nom.	Max
1 unit	5				5	3.300	0,97	5.500	1,61	6.050	1,77	235	380	472
	7				7	5.040	1,48	8.400	2,46	9.240	2,71	355	604	721
	9				9	6.480	1,90	10.800	3,17	11.880	3,48	454	784	949
	12				12	7.920	2,32	13.200	3,87	14.520	4,26	554	969	1.185
2 units	5	5			10	6.600	1,93	11.000	3,22	12.100	3,55	408	706	854
	5	7			12	7.920	2,32	13.200	3,87	14.520	4,26	498	872	1.066
	5	9			14	9.600	2,81	16.000	4,69	18.400	5,39	613	1.066	1.433
	7	7			14	9.600	2,81	16.000	4,69	18.400	5,39	613	1.066	1.433
	7	9			16	9.600	2,81	16.000	4,69	18.400	5,39	613	1.066	1.433
	5	12			17	9.600	2,81	16.000	4,69	18.400	5,39	613	1.066	1.433
	9	9			18	9.600	2,81	16.000	4,69	18.400	5,39	613	1.066	1.433
	7	12			19	9.600	2,81	16.000	4,69	18.400	5,39	613	1.066	1.433
	9	12			21	9.600	2,81	16.000	4,69	18.400	5,39	613	1.066	1.433