








[Unit: mm]

Chassis : U7

TBW35746501_Rev.01



Symbol



Piping Direction



Datum Line

Note

1. Unit should be installed in compliance with the installation manual in the product box.
2. Unit should be grounded in accordance with the local regulations or applicable national codes.
3. All electrical components and materials to be supplied from the site must comply with the local regulations or international codes.
4. Electrical characteristics chapter should be considered for electrical work and design. Especially the power cable and circuit breaker should be selected in accordance with that.

8	Power or communication Cable Holes	Ø 22
7	Power or communication Cable Holes	Ø 28
6	Power or communication Cable Holes	Ø 35
5	Drain Hole	Ø 20
4	Air Outlet	-
3	Air Inlet	-
2	Liquid piping connection	-
1	Gas piping connection	-
No.	Part Name	Description